

Report Function test pressure type leak detector

**Site
of facility**

Company _____

First name / last name _____

Street _____

Postcode / city _____

Product

Europress LAD-10 Approval for construction products: Z-65.23-3 (DIBt).

Europress Approval for construction products: Z-65.23-3 (DIBt) or CE as per EC Construction Products Regulation (EN 13160:2003) and ÜHP (declaration of conformity of the manufacturer after previous test performed by approved testing body).

Serial number

Measurement

Measurements of the switching points yielded the following results:

Alarm on: _____ mbar Pump on: _____ mbar

Alarm off: _____ mbar Pump off: _____ mbar

Checklist

- Results of visual inspection of the system: Installation as per instructions, no visible damage.
- The drying beads in the drying filter have been replaced or reconditioned.
- When the pressure dropped below the alarm threshold, the device triggered visual and audible alarms.
- When the test button was pressed, the device triggered visual and audible alarms.
- The audible alarm can be acknowledged.
- The operation and alarm lamps function properly.

12

Date of test:

**Specialised
company
as per WHG
(AwSV):**

Company _____

First name / last name _____

Street _____

Postcode / city _____

_____ Signature/stamp